




TO: All BIDDERS FROM: Selma Bukvic
OIC, Procurement Services Section

DATE: 18 November 2024 REF.: ITB No. 2024-0165/MAEDA YM

EMAIL: n/a EMAIL: procurement@ctbto.org 

SUBJECT: **Clarification No.2**
ITB No. 2024-0165/MAEDA: Supply and Delivery of Uninterruptable Power Supplies, Surge Protection Devices, Digital Voltage Stabilizers and Accessories to International Monitoring System Stations and Other Locations on a Call-off Basis

Dear Bidders,

Reference is made to the Invitation to Bid No. 2024-0165/MAEDA, “Supply and Delivery of Uninterruptable Power Supplies, Surge Protection Devices, Digital Voltage Stabilizers and Accessories to International Monitoring System Stations and Other Locations on a Call-off Basis” (the “ITB”).

- Please find attached **Clarifications No. 2** to questions raised by interested bidders;

Please take all of the above and attached documentation into account in the preparation and submission of your bid.

We are looking forward to receiving your bid prior to the deadline for the submission of bid of **Friday 22 November 2024 17:00 hours, Vienna (Austria) local time.**

Sincerely,



Selma Bukvic
OIC, Procurement Services Section

Attachments:

1. Clarifications No. 2

Clarifications No. 2

(Please note, the shaded questions/answers were already sent out as Clarifications No. 1)

ITB No. 2024-0165/MAEDA Supply and Delivery of Uninterruptable Power Supplies, Surge Protection Devices, Digital Voltage Stabilizers and Accessories to International Monitoring System Stations and Other Locations on a Call-off Basis Clarifications	
Question	Answers from the Commission
<p><u>Question 1</u></p> <p>The requirements:</p> <ul style="list-style-type: none"> - delivery to 337 (partly exotic-destinations, not even DHL is serving a big part of the destination), - warranty on all these locations - required delivery time (2 weeks dispatch) are impossible to fulfill. <p>Would you consider adjusting your requirements?</p>	<p><u>Answer 1</u></p> <p>Any issues will be discussed before the issuance of the relevant formal request for delivery (FRD), including any limitations, restrictions, risks and other delivery issues that may be identified at the time for a specific destination.</p> <p>Delivery may be required for any of the 337 destinations. The selected contractor shall do their best efforts to find the most effective delivery arrangement to relevant destinations and achieve a dispatch time of less than two (2) weeks following receipt of an FRD. In cases where this timeframe cannot be met due to remoteness or unforeseen circumstances, the contractor shall promptly notify the Commission and provide an updated estimated dispatch time. Again, this will all be discussed before the issuance of the FRD which will reflect the agreed arrangements for a specific destination.</p> <p>It should be also noted that, the Bidder can consider making use of official subsidiaries or distributors of equipment manufacturers in the regions or countries concerned.</p>
<p><u>Question 2</u></p> <p>Regarding Lot 2, Digital Voltage Stabilizers, could the Commission please name a brand they have identified that would be technically compliant?</p>	<p><u>Answer 2</u></p> <p>The Commission does not provide a brand name. Please propose any Digital Voltage Stabilizers which meet the requirements defined in Annex B Technical Specifications.</p>